



BRUHAT BENGALURU MAHANAGARA PALIKE

Ref: M.O.H/B/Pr/06/2022-23

Senior Health Inspector,
Ward No. 194, Gottigere,
Bommanahalli Zone, Begur Road,
BBMP, Bengaluru,
Date: 05th May'2022

To,
Skalvi International School,
No. 184, Muniswamyraju Layout,
Kothanur Main Road,
JP nagar 8th Phase,
Next To GR Lavender Apartments,
Bengaluru - 560078.

CERTIFICATE OF HYGIENE


Sir,

With reference to your letter dated 10th April 2022 to issue of certificate regarding cleanliness, Hygiene and availability of Drinking Water, Sanitary, Electricity of the Employees and Children in your School.


After due inspection and verification, we wish to inform you that we hereby confirm that the following facilities are available in your School and in good condition.

1. Drinking water available with RO facility in all floors.
2. Sanitary facility available as per children requirements in all floors.
3. Wall mounted electric connections are available in all floors.
4. School premises is hygienically maintained both in an around.

Validity: This certificate valid One year from the date of issue


Aff No.831032
Skalvi International School
184, Muniswamy Raju Layout, Kothnur,
JP Nagar 8th Phase, Bengaluru - 560 078.

Senior Health Inspector


Ward No. 194, Gottigere
Bommanahalli Zone,
Bengaluru Mahanagara Palike
05.05.2022

TEST REPORT

Sample Code: TCS06922000007497P	Date of Sampling	15.03.2022
Name Of the Organization : M/s. SKALVI INTERNATIONAL SCHOOL # 184, Muniswamy Raju Layout, Next to GR Lavender Apartment, Kothanur, J P Nagar 8th Phase, Bangalore - 560078	Date of Receipt	15.03.2022
	Date of Analysis Started	15.03.2022
	Date of Analysis Completed	18.03.2022
	Date of Report	22.03.2022
	Environmental Condition	Ambient
Sample Particulars : R. O Water	Sample Drawn By	Lab Representative
Source of Collection : Tap	Report No	TC506922000007497P
Sampling Method : IS 3025 (Part-1) 1987 - 2019 & IS 1622 :1981 - 2019	Condition of the Sample	Satisfactory

RESULTS

S. No	Parameters	Protocol	Results	Standards IS : 10500 - 2012	
				Desirable Limits	Permissible Limits
1	pH Value	IS 3025 (Part - 11) 2017	6.54	6.5-8.5	No Relaxation
2	Colour, Hazen Unit	IS 3025 (Part - 4) 2017	2.0	5.0 Max	15
3	Odour	IS 3025 (Part - 6) 2017	Agreeable	Agreeable	Agreeable
4	Turbidity, NTU	IS 3025 (Part - 10) 2017	0.1	1.0 Max	5.0 Max
5	Total Dissolved Solids, mg/L	IS 3025 (Part - 16) 2017	30.5	500 Max	2000 Max
6	Total Hardness as CaCO ₃ , mg/L	IS 3025 (Part - 21) 2019	16.0	200 Max	600 Max
7	Calcium as Ca, mg/L	IS 3025 (Part - 40) 2019	4.8	75 Max	200 Max
8	Magnesium as Mg, mg/L	IS 3025 (Part - 46) 2014	1.0	30 Max	100 Max
9	Alkalinity as CaCO ₃ , mg/L	IS 3025 (Part - 23) 2019	8.8	200 Max	600 Max
10	Chlorides as Cl, mg/L	IS 3025 (Part - 32) 2019	4.0	250 Max	1000 Max
11	Sulphates as SO ₄ , mg/L	IS 3025 (Part - 24) 2019	1.0	200 Max	400 Max
12	Nitrates as NO ₃ , mg/L	IS 3025 (Part - 34) 2019	3.6	45 Max	No Relaxation
13	Iron as Fe, mg/L	IS 3025 (Part - 53) 2019	0.07	1.0 Max	No Relaxation
14	Fluoride as F, mg/L	IS 3025 (Part - 60) 2019	0.1	1.0 Max	1.5
Microbiological Parameters					
15	E.coli, MPN/100ml	IS 1622 - 2019	Not Detected	Not Detectable	Not Detectable
16	Coliforms, MPN/100ml	IS 1622 - 2019	Not Detected	Not Detectable	Not Detectable

INFERENCE: As per IS Standards 10500 - 2012, The above tested results are within the limits.

Pavithra . R
ANALYZED BY

Pattar S
MICROBIOLOGIST

End of the Report



Krishna V
AUTHORISED SIGNATORY

KRISHNAVENI. K.
DY. Technical Manager

Note:

1. The results refer only to the tested samples and applicable Parameters
2. This report not to be reproduced wholly or in part & Cannot be used as an evidence in the Court of Law
3. Samples will be stored for a period of 15 Days on receipt. Gaseous samples, Food samples and Microbiology samples will be discarded after analysis
4. Nexus Test Labs doesnot hold any responsibility for variation in test results for samples kept on hold for want of clarification
5. Not Detected can be considered as absent
6. BDL - Below Detection Limits

NEXUS TEST LABS PVT. LTD.,

AK No. 831032
Skalvi International School
184, Muniswamy Raju Layout, Kothnur,
JP Nagar 8th Phase, Bengaluru - 560 078.

1 of 1